

**Summary of potential savings Jordan American Apparel Co.
(part II).**

#	Proposed Recommendation	Annual Energy Saving (KWh)	Cost Saving (JD/Year)	Investment Needed (JD)	Pay Back Period (Years)	Annual Co2 Reduction (ton)
1	Peak Demand-management	0	7000	0	Immediate	0
2	Lighting System	98160	4025	13959	3.5	75
3	Steam Boilers	820000 kWh _{th}	15000	4392	0.3	222
	Compressed Air System	909416	34000	Immediate	Immediate	690
4	Water System	1100000 kWh _{th}	12158	15000	1.2	297
	Total 2		72,183	33,351	0.46	1,284

a